

SaferFarm.org – Farm Hazard Analysis Tool

Ag Buildings

Power Outage

Least Protection

1. No power outage protection available.
2. Tractor PTO-powered generator available; no regular operation check; manual transfer switch to disconnect from main distribution line; no alarm system.
3. Tractor PTO-powered generator available; no regular operation check; automatic transfer switch to disconnect from main distribution line; no alarm system.
4. Automatic power generator professionally installed; operation tested semi-annually; automatic transferswitch to disconnect from main power distribution line; no alarms sounded when operating.
5. Automatic power generator professionally installed; operation tested semi-annually; automatic transferswitch to disconnect from main power distribution line; alarms sounded when operating.

Most Protection



Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____