

SaferFarm.org – Farm Hazard Analysis Tool

B&B Residential

Fire Detection/Suppression (Well Water)



Least Protection

1. No working smoke or heat detection system; smoking not restricted; fire escape/floor plan in each guest room; ABC fire extinguisher is available but not visible.
2. Battery powered; smoke detection system only; smoking restricted to specific areas; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits
3. Battery powered; smoke and heat detection system; no smoking permitted; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits
4. Electric circuit wired, battery back-up, on-site smoke and heat detection system; no smoking permitted; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits and heating and cooking areas.
5. Professionally installed and monitored fire detection system; no smoking permitted; fire escape/floor plan in each guest room; ABC fire extinguisher mounted near exits and heating and cooking areas.

Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____