

SaferFarm.org – Farm Hazard Analysis Tool

B&B Residential

Vegetation



Least Protection

1. Trees within 10 feet of building; flammable vegetation or combustible materials against building; many weed tree seedlings/saplings near building foundation.
2. Trees from 10-15 feet of building; flammable vegetation or combustible materials within 5 feet of building; a few weed tree seedlings/saplings near building foundation.
3. Trees 0.5 times mature height or more away from building; no flammable vegetation or combustible materials within 10 feet of building; no weed tree seedlings/saplings near building foundation.
4. Trees 1.0 times mature height or more away from building; no flammable vegetation or combustible materials within 20 feet of building; no weed tree seedlings/saplings near building foundation.
5. Trees 1.5 times mature height or more away from building; no flammable vegetation or combustible materials within 30 feet of building; no weed tree seedlings/saplings near building foundation.

Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____