

SaferFarm.org – Farm Hazard Analysis Tool

Other Structures/Accessories

Above Ground Fuel Storage



Least Protection

1. Gasoline tank is located next to buildings or other structures; tanks do not have double wall or spill and leak containment; tanks unprotected from vehicular contact; tanks rusted with signs of leakage.
2. Gasoline tank is located less than 40 feet from other buildings or structures; tanks do not have double walls or spill and leak containment; tanks unprotected from vehicular contact; some signs of leakage.
3. Gasoline tank is located at least 40 feet from other buildings or structures; some tanks without double walls or spill and leak containment; all tanks protected from vehicular contact ; no sign of leakage.
4. Gasoline tank is located at least 40 feet from other buildings or structures; all tanks have double walls and spill and leak containment; all tanks protected from vehicular contact in heavy ; no sign of leakage.
5. Gasoline tank is located at least 40 feet from other buildings or structures; all tanks have double walls and spill and leak containment; all tanks protected from vehicular contact; no signs of leakage.

Most Protection

Item:	Item:	Item:	Item:	Item:
<input type="radio"/> O1	<input type="radio"/> O1	<input type="radio"/> O1	<input type="radio"/> O1	<input type="radio"/> O1
<input type="radio"/> O2	<input type="radio"/> O2	<input type="radio"/> O2	<input type="radio"/> O2	<input type="radio"/> O2
<input type="radio"/> O3	<input type="radio"/> O3	<input type="radio"/> O3	<input type="radio"/> O3	<input type="radio"/> O3
<input type="radio"/> O4	<input type="radio"/> O4	<input type="radio"/> O4	<input type="radio"/> O4	<input type="radio"/> O4
<input type="radio"/> O5	<input type="radio"/> O5	<input type="radio"/> O5	<input type="radio"/> O5	<input type="radio"/> O5

Farm: _____

Inspector: _____

Date: _____