

SaferFarm.org – Farm Hazard Analysis Tool

Other Structures/Accessories

Gasoline Tank



Least Protection

1. Gasoline tank is located next to other buildings or structures; no tanks have double wall or a containment structure or earthen dike; no tank is protected from vehicular contact; some tanks and accessories show much leakage.
2. Gasoline tank is located less than 40 feet from other buildings or structures; no tanks have double walls or a containment structure or earthen dike; no tanks are protected from vehicular contact; some tanks and accessories show some leakage.
3. Gasoline tank is located at least 40 feet from other buildings or structures; some tanks do not have double walls or a containment structure or earthen dike; all tanks are protected from vehicular contact; no tank/accessory leaks.
4. Gasoline tank is at least 40 feet from other buildings or structures; all tanks have double walls or set in a containment structure or earthen dike; all tanks are protected from vehicular contact in heavy traffic areas only; no tank/accessory leaks.
5. Gasoline tank is located at least 40 feet from other buildings or structures; all tanks have double walls or set in a containment structure or earthen dike; all tanks are protected from vehicular contact; no tank or accessory leaks.



Most Protection

Item:	Item:	Item:	Item:	Item:
O1	O1	O1	O1	O1
O2	O2	O2	O2	O2
O3	O3	O3	O3	O3
O4	O4	O4	O4	O4
O5	O5	O5	O5	O5

Farm: _____

Inspector: _____

Date: _____